



**SAINT LOUIS COUNTY**  
Transportation and Public Works

Office of Electrical Inspection  
Generator Load Sheet

June 2, 2023

**Line 1:** What is the total computed load for the home? \_\_\_\_\_AMPS

**Line 2:** What is the total output for the generator? \_\_\_\_\_AMPS

**Line 2 is the number provided by the manufacturer that the generator can perform at continuously.**

**If Line 1 is greater than Line 2 shedding will be allowed to bring the load down to meet the generators' ability to meet Line 1.**

**Line 3:** What is the shredded computed load? \_\_\_\_\_AMPS

**Line 3 is the amount of the total reduction that shedding devices will provide.**

**Line 4:** Subtract Line 3 from Line 1. \_\_\_\_\_AMPS

**If Line 4 is smaller than Line 2 you can use this generator in this installation. This form will be filled out by the electrical contractor and provided to Saint Louis County Inspector at time of inspection. If Line 4 requirements are met it will be used in the approval process. A copy of this sheet will be placed with the generator. In addition, the customer will also be provided with a copy for their records.**

Address of installation:

\_\_\_\_\_

Customer: \_\_\_\_\_ Date: \_\_\_\_\_

Contractor: \_\_\_\_\_ Date: \_\_\_\_\_

**If you have any questions, please feel free to send me an email with your inquiries at [jperlongo@stlouiscountymo.gov](mailto:jperlongo@stlouiscountymo.gov).**

**John Perlongo, Assistant Chief Electrical Inspector**